

Certificate of Conformity

By the product certificate number:

No. 2622/0478-E-CER

Issued to

License holder:

Victron Energy B. V.
De Paal 35, 1351 JG Almere – Netherlands

Trademark:



Contract number:

802190

It is certified that the product:

Type of product: Inverter/Charger with UPS functionality

Models:	MultiPlus-II 48/8000/110-100 230V	MultiPlus-II 48/10000/140-100 230V	MultiPlus-II 48/15000/200-100 230V
Rated characteristics:			
Rated AC Power	8 kVA / 6.4 kW	10 kVA / 8 kW	15.0 kVA / 12.0 kW
Rated AC Voltage		AC input: 187-250 V _{ac} DC input: 38-66 V _{dc} AC output: 220-240 V _{ac} DC output: 48 V _{dc}	
Rated AC Frequency		50 Hz	
Firmware version	2621502	2627502	2619502
Number of phases		Single Phase (L/N/PE)	
Isolation transformer		Yes	

Is in compliance with product requirements of the standard:

- **OVE-Richtlinie R 25:2020-03-01.** Prüfanforderungen an Erzeugungseinheiten (Generatoren) vorgesehen zum Anschluss und Parallelbetrieb an Niederspannungs-Verteilernetzen / *Test requirements for generator units to be connected to and operated in parallel with low-voltage distribution network*

Taking into account the applicable requirements of the standards:

- **TOR D2, (Version 2.4),** Technische und organisatorische Regeln für Betreiber und Benutzer von Netzen – Teil D: Besondere technische Regeln – Hauptabschnitt D2: Richtlinie zur Beurteilung von Netzzrückwirkungen.
- **TOR Erzeuger: 2022-04-18 Typ A,** Anschluss und Parallelbetrieb von Stromerzeugungsanlagen des Typs A und von Kleinsterzeugungsanlagen. (Maximalkapazität < 250 kW und Nennspannung < 110 kV) / *Connection and parallel operation of type A power generation plants and micro generation plants (maximum capacity < 250 kW and nominal voltage < 110 kV)*

The above-mentioned generating unit is certified according to the SGS internal process PE.T-ECPE-71 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate is first issued on 21st of February 2024.

This certificate is valid until the 21st of February 2029.

Madrid, 21st February 2024

Daniel Arranz Muñiz
Certification Manager

